

DATE

09/08/2024

PRODUCER

R.E.M. SRL

CUSTOMER

A.R.I.A

PRODUCT

MOTORE BROOK CROMPTON 7U
DF180M 4 N COMM 2024 0622 N

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.53121	25.93	PASS	7.7	0	PASS
Phase 2			0.53112		PASS			
Phase 3			0.53112		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1500	3.8	5.652 m	0.2	5	65.71	0	GO	99.8
Phase 2	1500		5.652 m			65.71		GO	
Phase 3	1500		5.661 m			65.71		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1576	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1055	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	964	500	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

