

DATE

03/10/2024

PRODUCER

R.E.M. SRL

CUSTOMER

HYDRO SLIM

PRODUCT

N_COMM 2024_0694 N_REM 10924
TP_ABB M2CA355MA4 B3

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.0098	21.17	PASS	7.7	0.2	PASS
Phase 2			0.00982		PASS			
Phase 3			0.00982		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1285	3.8	624.4 u	0.2	5	34.92	0	GO	99.8
Phase 2	1285		625.9 u			34.92		GO	
Phase 3	1285		625.9 u			34.92		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1091	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1093	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	964	535	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

