

DATE

01/10/2024

PRODUCER

R.E.M. SRL

CUSTOMER

IFIS

PRODUCT

POMPA LOWARA PLM160B34S3
3150 E3 N COMM 2024 0686 N

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.45147	19.53	PASS	7.7	0.2	PASS
Phase 2			0.45147		PASS			
Phase 3			0.45244		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1500	3.8	6.392 m	2.1	5	67.57	2.7	GO	95.2
Phase 2	1500		6.497 m			69.44		GO	
Phase 3	1500		6.526 m			69.44		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1055	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1055	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	910	482	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

