

DATE

29/10/2024

PRODUCER

R.E.M. SRL

CUSTOMER

IFIS

PRODUCT

POMPA LOWARA PLM160B34S3
3150 E3 N COMM 2024 0686 N

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.45262	18.33	PASS	7.7	0.2	PASS
Phase 2			0.45262		PASS			
Phase 3			0.45361		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1478	3.8	6.521 m	2.1	5	66.67	2.4	GO	95.5
Phase 2	1478		6.492 m			68.33		GO	
Phase 3	1478		6.382 m			68.33		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	876.8	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1080	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	928	500	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

