

DATE

24/12/2024

PRODUCER

R.E.M. SRL

CUSTOMER

INDUSTRIA CARTARIA TIVOLI

PRODUCT

COMELMAR N_98281 Comm 2024
0875

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.01737	15	PASS	7.7	0.4	PASS
Phase 2			0.01742		PASS			
Phase 3			0.01744		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1185	3	798.1 u	1.5	7.5	36.84	1.7	GO	96.8
Phase 2	1185		793.0 u			36.84		GO	
Phase 3	1185		804.9 u			36.21		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1091	0.004	0.56	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1093	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	750	321	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

