

DATE

11/12/2024

PRODUCER

R.E.M. SRL

CUSTOMER

INDUSTRIA CARTARIA TIVOLI

PRODUCT

COMELMAR EFACEC BF4250M4
N°Comm 2024-0936

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.0696	15.8	PASS	7.7	2.1	PASS
Phase 2			0.06968		PASS			
Phase 3			0.06828		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1457	2.5	1.416 m	0.5	7.5	50	3.6	GO	95.9
Phase 2	1457		1.409 m			51.85		GO	
Phase 3	1457		1.409 m			51.85		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	850	0.004	0.56	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1029	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	785	321	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

