

DATE

16/02/2024

PRODUCER

R.E.M. SRL

CUSTOMER

INTERNATIONAL PAPER

PRODUCT

AEG AMPE 200L RG4 N_141104142
Comm 2024 0103

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.20978	15.49	PASS	7.7	0.4	PASS
Phase 2			0.20978		PASS			
Phase 3			0.21057		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1521	5.2	3.850 m	0.1	6	60.71	0	GO	99.9
Phase 2	1521		3.854 m			60.71		GO	
Phase 3	1521		3.854 m			60.71		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1079	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1080	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	928	500	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

