

DATE

18/01/2024

PRODUCER

R.E.M. SRL

CUSTOMER

HYDRO

PRODUCT

MOT TARGA POCO LEGGIBILE 280
S 4_8 N_F 6565 Comm 2024 0029

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.16433	15.93	PASS	7.7	0.4	PASS
Phase 2			0.16374		PASS			
Phase 3			0.16371		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1321	5.2	2.875 m	0.9	6	51.72	3.4	GO	95.7
Phase 2	1321		2.887 m			53.57		GO	
Phase 3	1321		2.862 m			51.72		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1104	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1105	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	857	464	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

