

DATE

12/02/2024

PRODUCER

R.E.M. SRL

CUSTOMER

HYDRO ALLUMINIUM SLIM

PRODUCT

VENTILATORE SIEMENS
1LA52062AA60 Z N COMM 2023

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.2413	15	PASS	7.7	0	PASS
Phase 2			0.2413		PASS			
Phase 3			0.2413		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1478	5.2	4.279 m	0.2	6	56.36	0	GO	99.8
Phase 2	1478		4.275 m			56.36		GO	
Phase 3	1500		4.271 m			56.36		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1053	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1055	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	928	500	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

