

DATE

20/06/2024

PRODUCER

R.E.M. SRL

CUSTOMER

ITALCEMENTI

PRODUCT

ROTORE BBC M400LN6 N°Comm
2024-0193

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.02868	26.6	PASS	7.7	0.7	PASS
Phase 2			0.02867		PASS			
Phase 3			0.02887		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1342	3.8	1.647 m	0.6	5	56.34	0	GO	99.4
Phase 2	1342		1.647 m			56.34		GO	
Phase 3	1342		1.657 m			56.34		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1066	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1118	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	750	450	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

