

DATE

20/06/2024

PRODUCER

R.E.M. SRL

CUSTOMER

ITALCEMENTI

PRODUCT

STATORE BBC M400LN6 N°Comm
2024-0193

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	1.66227	27.75	PASS	7.7	0	PASS
Phase 2			1.66199		PASS			
Phase 3			1.66199		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	4928	3.8	169.7 m	1.2	5	70.31	0	GO	98.8
Phase 2	4928		168.8 m			70.31		GO	
Phase 3	4928		170.9 m			70.31		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	6201	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	6213	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

