

DATE

05/09/2024

PRODUCER

R.E.M. SRL

CUSTOMER

LEONARDO

PRODUCT

WEG 160L 04 N_1047620839 Comm
2024 0691

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.6878	23.8	PASS	7.7	0	PASS
Phase 2			0.68768		PASS			
Phase 3			0.68768		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1500	3.8	5.418 m	0.1	5	66.67	0	GO	99.9
Phase 2	1500		5.413 m			66.67		GO	
Phase 3	1500		5.418 m			66.67		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1144	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1131	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	1017	535	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

