

RESISTANCE TEST

|         | R min | R max | R       | Temperature | Result | max dR % | dR % | Result dR |
|---------|-------|-------|---------|-------------|--------|----------|------|-----------|
| Phase 1 | 0     | 99999 | 0.01057 | 27.88       | PASS   | 7.7      | 0.2  | PASS      |
| Phase 2 |       |       | 0.01058 |             | PASS   |          |      |           |
| Phase 3 |       |       | 0.01059 |             | PASS   |          |      |           |

SURGE TEST

|         | V    | Toll% L | L       | dL % | Toll% Q | Q     | dQ % | Result | T Q F % |
|---------|------|---------|---------|------|---------|-------|------|--------|---------|
| Phase 1 | 1171 | 3.8     | 544.8 u | 0    | 5       | 33.9  | 1.7  | GO     | 98.3    |
| Phase 2 | 1171 |         | 544.8 u |      |         | 33.9  |      | GO     |         |
| Phase 3 | 1171 |         | 544.8 u |      |         | 33.33 |      | GO     |         |
| Sample  | 0    |         | 0       |      |         | 0     |      |        |         |

H. V. TEST

|  | V (V) | I Max (A) | I Meas(A) | Result |
|--|-------|-----------|-----------|--------|
|  | 1055  | 0         | 2         | GO     |

MEGAOHMMETER TEST

|  | V (V) | R Min [MOhm] | R Meas [MOhm] | Result |
|--|-------|--------------|---------------|--------|
|  | 1067  | 1000         | 5             | GO     |

SURGE 1.2/50 TEST

|  | V PK (V) | V 50u | Result |
|--|----------|-------|--------|
|  | 750      | 392   | GO     |

POLARIZATION INDEX TEST

|  | V PK (V) | Ri | Rf | K | Time (s) |
|--|----------|----|----|---|----------|
|  |          |    |    |   |          |

