

DATE

21/11/2024

PRODUCER

R.E.M. SRL

CUSTOMER

MAIELLARO

PRODUCT

MOTOVIBRATORE N° Comm 2024
0851 N° Rem 16765

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.24527	13.58	PASS	7.7	0.1	PASS
Phase 2			0.24505		PASS			
Phase 3			0.24509		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1800	3.8	3.200 m	0.2	5	60	1	GO	98.8
Phase 2	1800		3.206 m			60		GO	
Phase 3	1778		3.203 m			59.38		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1042	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1067	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	892	464	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

