

DATE

30/07/2024

PRODUCER

R.E.M. SRL

CUSTOMER

BURGO AVEZZANO

PRODUCTSTATORE UNELEC N2R400K51
N_225482741 Comm 2024 0598**RESISTANCE TEST**

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.00399	27.22	PASS	7.7	0.6	PASS
Phase 2			0.00396		PASS			
Phase 3			0.00396		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	900	3.8	491.5 u	0.8	5	42.37	1.7	GO	97.5
Phase 2	900		491.5 u			41.67		GO	
Phase 3	910		495.5 u			41.67		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1106	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1106	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	571	321	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

