

DATE

05/08/2024

PRODUCER

R.E.M. SRL

CUSTOMER

MAD SRL

PRODUCT

STATORE UNELEC N2R400K51
N_225482741 Comm 2024 0598

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.00402	26.77	PASS	7.7	0.3	PASS
Phase 2			0.00402		PASS			
Phase 3			0.00403		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	921	3.8	499.6 u	0.3	5	42.37	1.7	GO	98
Phase 2	921		500.9 u			41.67		GO	
Phase 3	921		500.9 u			42.37		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1093	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1093	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	571	321	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

