

DATE

29/11/2024

PRODUCER

R.E.M. SRL

CUSTOMER

RIEM

PRODUCT

ABB HXR450MH N°4546187
N°Comm 2024-0890

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.15061	13.93	PASS	7.7	0.5	PASS
Phase 2			0.15041		PASS			
Phase 3			0.14981		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	3642	2.5	50.88 m	1.5	7.5	72.22	6.1	GO	92.4
Phase 2	3571		51.68 m			76.92		GO	
Phase 3	3642		51.25 m			72.22		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	4065	0.004	0.56	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	4066	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

