

DATE	PRODUCER	CUSTOMER	PRODUCT
02/12/2024	R.E.M. SRL	RIEM	ABB HXR450MH N°4546187 N°Comm 2024-0890

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.16999	13.71	PASS	7.7	0.2	PASS
Phase 2			0.17036		PASS			
Phase 3			0.17019		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	3071	2.5	52.40 m	0.8	7.5	79.07	3.4	GO	95.8
Phase 2	3071		52.48 m			79.55		GO	
Phase 3	3107		52.06 m			81.82		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	5908	0.004	0.56	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	6111	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

