

DATE

07/10/2024

PRODUCER

R.E.M. SRL

CUSTOMER

ROMACH

PRODUCT

L37 YPG200L2 2 B34 N COMM
2024 0487 N REM 16603

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.14558	20.51	PASS	7.7	1.9	PASS
Phase 2			0.14284		PASS			
Phase 3			0.14458		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1571	3.8	3.521 m	1.6	5	57.14	0	GO	98.4
Phase 2	1571		3.464 m			57.14		GO	
Phase 3	1571		3.464 m			57.14		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1053	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1055	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	878	450	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

