

DATE	PRODUCER	CUSTOMER	PRODUCT
12/08/2024	R.E.M. SRL	SALCEF	ROTORE ECCITATRICE GENERATORE M1B 250 MB4

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.15748	28.68	PASS	7.7	1	PASS
Phase 2			0.15596		PASS			
Phase 3			0.15691		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	535	3.8	771.3 u	0.6	5	36.84	0	GO	99.4
Phase 2	535		776.3 u			36.84		GO	
Phase 3	535		773.0 u			36.84		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	521	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	521	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	482	267	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

