

DATE

09/08/2024

PRODUCER

R.E.M. SRL

CUSTOMER

SALCEF

PRODUCT

GENERATORE M1B 250 MB4
Comm 2024 0628

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.02312	28.55	PASS	7.7	2.3	PASS
Phase 2			0.0226		PASS			
Phase 3			0.02302		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1564	3.8	239.9 u	0.4	5	23.91	2.2	GO	97.4
Phase 2	1564		239.9 u			24.44		GO	
Phase 3	1564		240.8 u			23.91		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1067	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1055	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	821	464	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

