

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.19071	15.17	PASS	7.7	0.2	PASS
Phase 2			0.19091		PASS			
Phase 3			0.19111		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1400	2.5	4.440 m	0.8	5	53.25	1.3	GO	97.9
Phase 2	1400		4.416 m			53.25		GO	
Phase 3	1400		4.405 m			53.95		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1093	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1093	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	928	500	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

