

DATE

18/10/2024

PRODUCER

R.E.M. SRL

CUSTOMER

SORGENIA

PRODUCT

ABB M3BP315MLA N Comm 2024
0788 N Rem 16742 (prima del

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.01528	19.4	PASS	7.7	0.2	PASS
Phase 2			0.01525		PASS			
Phase 3			0.01526		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1171	3.8	944.5 u	0.4	5	44.07	0	GO	99.6
Phase 2	1171		944.5 u			44.07		GO	
Phase 3	1171		940.8 u			44.07		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1144	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1144	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	696	267	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

