

DATE

17/06/2024

PRODUCER

R.E.M. SRL

CUSTOMER

A R I A

PRODUCT

FELM Y2VP400L2-4 GIRI 1490 N
COMM 2024 0463 N REM 15797

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.00287	22.28	PASS	7.7	1.7	PASS
Phase 2			0.0029		PASS			
Phase 3			0.00285		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	835	3.8	389.6 u	0.9	5	32.26	0	GO	99.1
Phase 2	846		388.4 u			32.26		GO	
Phase 3	846		386.0 u			32.26		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1041	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1042	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	492	257	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

