

DATE

04/10/2024

PRODUCER

R.E.M. SRL

CUSTOMER

TEFIN

PRODUCT

SCHORCH BN5318M PZ519 Z N
COMM 2024 0746 N REM 16725

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.03601	18.6	PASS	7.7	2.1	PASS
Phase 2			0.03616		PASS			
Phase 3			0.03543		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1357	3.8	1.221 m	0.3	5	46.58	1.4	GO	98.3
Phase 2	1357		1.223 m			46.58		GO	
Phase 3	1357		1.219 m			47.22		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1080	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1080	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	857	482	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

