

DATE

29/11/2024

PRODUCER

R.E.M. SRL

CUSTOMER

TEFIN

PRODUCT

BEN KDKF380 N°Comm 2024-0892
U3-V3-W3

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.50271	14.46	PASS	7.7	2	PASS
Phase 2			0.49263		PASS			
Phase 3			0.50162		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1564	2.5	11.48 m	0.2	7.5	62.71	0	GO	99.8
Phase 2	1564		11.48 m			62.71		GO	
Phase 3	1585		11.46 m			62.71		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1041	0.004	0.56	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1042	650.6	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	892	500	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

