

DATE

02/01/2025

PRODUCER

R.E.M. SRL

CUSTOMER

TEFIN

PRODUCT

Terminale A2 ARMATURA MOT
6POLI Comm 2024-0893

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.01108	16.55	PASS	7.7	17783	PASS
Phase 2			0.01106		PASS			
Phase 3			0		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1052	0.009	0.56	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1051	74.3	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	964	482	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

