

DATE

03/07/2024

PRODUCER

R.E.M. SRL

CUSTOMER

TESTI CEMENTI

PRODUCT

ABB HXR 355LA 6 B3 N°Conn 2024-0238

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.02493	24.86	PASS	7.7	0.4	PASS
Phase 2			0.02489		PASS			
Phase 3			0.02498		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1178	3.8	1.457 m	1.2	5	48.57	0	GO	98.8
Phase 2	1178		1.475 m			48.57		GO	
Phase 3	1178		1.473 m			48.57		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1117	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1118	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	1028	514	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

