

DATE

01/07/2024

PRODUCER

R.E.M. SRL

CUSTOMER

TESTI CEMENTI

PRODUCT

STROMBERG DRIVES XHR 400MH6
N°Comm 2024-0239

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.00686	29.13	PASS	7.7	0	PASS
Phase 2			0.00686		PASS			
Phase 3			0.00686		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1185	3.8	554.6 u	0	5	38.6	1.7	GO	98.3
Phase 2	1185		554.6 u			38.6		GO	
Phase 3	1185		554.6 u			37.93		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1093	0	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1080	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	685	385	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

