

DATE	PRODUCER	CUSTOMER	PRODUCT
30/01/2025	R.E.M. SRL	FCA CASSINO	ROTORE ASGEN N_COMM 2024_0906N N_REM16799

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.00831	13.04	PASS	7.7	2.6	PASS
Phase 2			0.0084		PASS			
Phase 3			0.00852		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1142	3	504.9 u	0.5	7.5	41.82	0	GO	99.5
Phase 2	1142		507.6 u			41.82		GO	
Phase 3	1142		507.6 u			41.82		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1117	0.004	0.56	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1118	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	803	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

