

DATE

14/01/2025

PRODUCER

R.E.M. SRL

CUSTOMER

CETEC

PRODUCT

MOTORE CETEC N COM 25 0023 N
REM 16860

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.20417	15.84	PASS	7.7	0.3	PASS
Phase 2			0.20424		PASS			
Phase 3			0.20471		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1371	3	3.674 m	0.3	7.5	58.49	3.2	GO	96.5
Phase 2	1350		3.671 m			56.6		GO	
Phase 3	1350		3.664 m			56.6		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	951.6	0.004	0.56	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	965.7	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	857	482	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

