

DATE

07/01/2025

PRODUCER

R.E.M. SRL

CUSTOMER

SORGENIA

PRODUCT

MARELLI A4Q 180 M2 V1 N
W011867 N COMM 250008 N REM

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.40806	14.2	PASS	7.7	0.2	PASS
Phase 2			0.40713		PASS			
Phase 3			0.40713		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1457	3	5.506 m	2.6	7.5	62.07	0	NO GO	97.4
Phase 2	1457		5.506 m			62.07		NO GO	
Phase 3	1435		5.361 m			62.07		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1079	0.004	0.56	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1080	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	964	482	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

