




Cursore Principale	X [Hz]	= Non Attivo	(49,77) Unbalance Unbalance
	Y [mm/s]	= Non Attivo	
Cursore delta	X [Hz]	= Non Attivo	
	Y [mm/s]	= Non Attivo	
RPM		= 2986	
RMS	Y [mm/s]	= 1,76	



Date/Time

17/07/2019 16:26:42

Page 2 of 2

Canale #	A	
	X [Hz]	Y [mm/s]
1	100,00	1,01
2	50,00	0,91
3	149,75	0,51
4	68,50	0,30
5	67,50	0,20
6	249,75	0,19
7	499,50	0,19
8	139,75	0,17
9	140,25	0,17
10	142,50	0,16