




Type	kW	V	A	Hz	r/min	η(%)	cosφ	T _{max} /T _n	T _{st} /T _n	I _{st} /I _n	Ins.CL	Conn	Rtg	IM	IP	Bearing DE	Bearing NDE
315-4	250	6000	30.3	50	1485	93.4	0.85	1.8	0.7	6.5	F	Y	S1	B3	23	6319 C3	6319 C3

A - A

