

DATE

02/01/2015

PRODUCER

REM SRL

CUSTOMER

BURGO GROUP SORA

PRODUCT

Siemens 1RA6317-4AC51-Z315L

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0.015	1	0.02464	7.754	PASS	5	0	PASS
Phase 2			0.02464		PASS			
Phase 3			0.02464		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	957		983.4 u			41.3		GO	
Phase 2	957		992.8 u			40.43		GO	
Phase 3	971		998.5 u			40.43		GO	
Sample									

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1549	0.004	0.408	GO

MEGAOHMMETER TEST

	V (V)	R Min [kOhm]	R Meas [kOhm]	Result
	1550	1000	45	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

