

DATE

27/12/2016

PRODUCER

R.E.M. SRL

CUSTOMER

BURGO SORA

PRODUCT

SIEMENS 1LA8355_4PB50

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.01398	10.11	PASS	5	0.2	PASS
Phase 2			0.01395		PASS			
Phase 3			0.01395		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1028	2.5	1.107 m	1.4	5	42.11	0	GO	98.6
Phase 2	1028		1.117 m			42.11		GO	
Phase 3	1050		1.101 m			42.11		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1053	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [kOhm]	R Meas [kOhm]	Result
	1055	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	600	257	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

