

DATE

13/08/2015

PRODUCER

R.E.M. SRL

CUSTOMER

BUZZI UNICEM

PRODUCT

ROTORE TIBB Tp.SD630kb6
KW2200 N°M420013 N°Rem12669

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.00002	31.26	PASS	6	0	PASS
Phase 2			0.00002		PASS			
Phase 3			0.00002		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	971	4	3.305 m	2.5	10	74.51	2	GO	95.5
Phase 2	1071		3.332 m			76		GO	
Phase 3	985		3.250 m			74.51		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1080	0	0.3	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1080	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	1007	514	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

