

DATE

21/10/2020

PRODUCER

R.E.M. SRL

CUSTOMER

CONSORZIO DI BONIFICA

PRODUCT

STATORE TECNOMASIO
MVRP2616 N°Comm 2020 0493

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	999999	0.07609	15.22	PASS	6.3	0.4	PASS
Phase 2			0.07641		PASS			
Phase 3			0.07641		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1414	4	2.271 m	0.9	10.9	37.31	0	GO	99.1
Phase 2	1414		2.271 m			37.31		GO	
Phase 3	1414		2.291 m			37.31		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1118	0	1.288	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1118	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	835	492	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

