ITEM	DESCRIPTION	Q тү
1	ANSALDO Three Phase Motor (Stator Winding).	
	Type: CT 800 W6	
	Rating: 2900KW , 994RPM , 6.3KV, 3Phase	_
	Amp: 322A Service Factor 1	1
	Class of Insulation: Nema F	
	Duty: Cont Ambient Temp: 47C	
	Ambient Temp. 47C	
	Scope of work:-	
	A – Stator:-	
	* Supply Original Stator windings complete of frame suitable for CT 800 W6 - S/N 61166 .	
	* Stator insulating will be using vacuum pressure impregnation (VPI) method, class F.	
	* Testing of winding resistance insulation will be carried out according IEC regulations.	
	B – Rotor:- Mechanical tests (dynamic balance – axial displacement) will be done on rotor and preparing for safe operation. Rotor should be delivered with motor in good condition.	
	C -Bearing:-	
	Inspecting of bearings and fan cover and making the necessary rehabilitation to adjust vibration values within the accepted limits according to international	
	standards. Replace the bearing housing & motor bearing (Sleeve bearing) with new one.	
	D – Assembled motor:-	
	The motor vibration values in the different directions should be within the accepted limits according to international standards, a safe operation of the motor should be guaranteed.	
	E – Complete motor electrical tests:-	
	Motor complete electrical tests will be done and test report will be submitted including the following test results:	
	1 – Short circuit current test	
	2 – Insulation resistance test	
	3 – High potential test and leakage current 4 – All temperature detectors testing	
	1 7 All temperature detectors testing	

ITEM	DESCRIPTION	Qтү
	Scope of work will includes:-	
	 Carry out as received electrical checks prior to dismantling. Mark the coupling location and dismantle the motor complete inspect all parts and prepare an inspection report accordingly. Cleaning 	
	Check of all mechanical parts	
	Check of the sleeve bearings	
	 Carry out the polarity of the windings and strip down the complete damaged 	
	windings. Removal of the old damaged winding with Pyrolyse	
	 Cleaning slots and wedge keyways to ensure correct fit of the coils and the wedge. Mounting of 6 x PT100 in the winding 	
	 Carry out T.I.R concentricity checks on the rotor shaft, check the rotor bars S.C rings using NDT. 	
	 Clean the rotor chemically; check the brazing on both ends of each rotor shorting 	
	ringCheck the bearing fits on the housing and the bearing journals.Quality check of the new stator winding	
	 Reassemble the complete motor with new bearings. 	
	Assembling	
	Test run the motor at rated voltage of 6KV	
	New painting of the motor.Complete motor check.	
	No Load test.	
	Resistance check.	
	■ Vibration check.	
	Bearings check.	
	 Documentation in a complete test protocol. 	
	- The following test will be carried out on the above motor:-	
	a. Individual phase winding resistance.	
	b. Individual and complete winded IR/PI.	
	c. Current and speed recording.	
	d. Vibration and temperatures.	
	e. 100% Impulse test.	
	f. Partial discharge.	
	g. Final HV flash.	

PHOTOS













Print to PDF without this message by purchasing novaPDF (http://www.novapdf.com/)