

DATE

03/09/2015

PRODUCER

R.E.M. SRL

CUSTOMER

HYDRO SLIM

PRODUCT

MARELLI Tp 280S 4-8 N°F6561
Kw51-31 N°Rem 11347

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0.08	0.15	0.12333	26.15	PASS	5	1.1	PASS
Phase 2			0.12197		PASS			
Phase 3			0.12216		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1285	3	2.342 m	1.4	8	50	2.9	GO	95.7
Phase 2	1285		2.311 m			51.52		GO	
Phase 3	1285		2.337 m			50		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1079	0.004	0.3	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1080	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	800	442	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

