




Date/Time 04/03/2021 14:26:15

Page 1 of 2

Data e ora della misurazione 03/03/2021 16:24:27

REM\ITALCHEMICAL\POMPA OLIO CALDO\MOTOREM2H\m2h.sracas



Cursore Principale	X [Hz]	= Non Attivo
	Y [m/s ²]	= Non Attivo
Cursore delta	X [Hz]	= Non Attivo
	Y [m/s ²]	= Non Attivo
RPM		= 2940
RMS	Y [m/s ²]	= 24,06



Date/Time

04/03/2021 14:26:16

Page 2 of 2

Canale #	A	
	X [Hz]	Y [m/s ²]
1	1375,50	23,118
2	2551,00	2,457
3	1275,50	2,182
4	1326,50	2,022
5	1424,63	1,882
6	49,00	1,833
7	1473,63	1,738
8	1522,63	1,388
9	2751,00	1,376
10	1571,75	1,068