




Cursore Principale	X [Hz]	= 49,50	(49,00) Unbalance Unbalance
	Y [mm/s]	= 6,19	
Cursore delta	X [Hz]	= Non Attivo	
	Y [mm/s]	= Non Attivo	
RPM		= 2940	
RMS	Y [mm/s]	= 6,30	



Date/Time

16/01/2019 13:52:21

Page 2 of 2

Canale #	A	
	X [Hz]	Y [mm/s]
1	49,50	6,19
2	48,50	1,02
3	19,75	0,16
4	100,00	0,14
5	38,63	0,13
6	39,38	0,13
7	145,50	0,12
8	39,75	0,12
9	37,88	0,12
10	19,38	0,12