




Date/Time 15/05/2020 14:01:14

Page 1 of 2

Data e ora della misurazione 08/05/2020 14:28:56

REM\NAPOLI NORD\SOFFIANTE HOFFMANN B\TURBOSOFFIANTE\S1V\1060 Mach.spectr. > 600



Cursore	X [Hz]	= 49,75
Principale	Y [mm/s]	= 0,28
Cursore delta	X [Hz]	= 99,50
	Y [mm/s]	= 0,09
RPM		= 2983
RMS	Y [mm/s]	= 0,78



Date/Time

15/05/2020 14:01:15

Page 2 of 2

Canale #	A	Y [mm/s]
	X [Hz]	
1	100,00	0,58
2	49,75	0,28
3	154,00	0,28
4	2,00	0,11
5	199,25	0,09
6	782,75	0,08
7	149,50	0,06
8	3,25	0,06
9	271,50	0,06
10	427,75	0,06