




Date/Time 21/01/2021 12:20:38

Page 1 of 2

Data e ora della misurazione 20/10/2020 12:46:36

REM\NAPOLI NORD\SOFFIANTE HOFFMANN F\TURBOSOFFIANTE\S1H\1060 Mach.spectr. > 600



Cursore	X [Hz]	= 49,75
Principale	Y [mm/s]	= 0,85
Cursore delta	X [Hz]	= 149,25
	Y [mm/s]	= 0,20
RPM		= 2983
RMS	Y [mm/s]	= 1,13



Date/Time

21/01/2021 12:20:39

Page 2 of 2

Canale #	A	
	X [Hz]	Y [mm/s]
1	49,75	0,85
2	100,00	0,50
3	149,50	0,33
4	299,00	0,19
5	348,75	0,17
6	154,00	0,14
7	99,25	0,09
8	295,50	0,08
9	2,00	0,08
10	199,25	0,08