

DATE

26/10/2015

PRODUCER

R.E.M.SRL 12685

CUSTOMER

RIEM SERVICE S.R.L.

PRODUCT

SIEMENS 1LA8357-4PB91 N
VD117678301 0001 Mors 1-6

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0.004	0.007	0.00631	14.38	PASS	5	4	PASS
Phase 2			0.00611		PASS			
Phase 3			0.00607		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %
Phase 1	1228	3.2	340.2 u	1.6	8.9	24.07	7.1	GO	91.3
Phase 2	1242		334.7 u			25.93		GO	
Phase 3	1242		334.7 u			25.45		GO	
Sample	0		0			0			

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1665	0	0.604	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1652	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	1142	542	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

