

DATE

21/04/2015

PRODUCER

R.E.M. SRL

CUSTOMER

SORGENIA APRILIA

PRODUCT

ABB10PGB11AP001

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	9999	0.01534	14.64	PASS	5	0.1	PASS
Phase 2			0.01533		PASS			
Phase 3			0.01532		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1600	0.004	0.3	GO

MEGAOHMMETER TEST

	V (V)	R Min [kOhm]	R Meas [kOhm]	Result
	1588	1000	45	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

