

## DATE

16/04/2015

## PRODUCER

R.E.M. SRL

## CUSTOMER

SORGENIA APRILIA

## PRODUCT

ABB13MAG10AN004MATR.36C

## RESISTANCE TEST

|         | R min | R max | R       | Temperature | Result | max dR % | dR % | Result dR |
|---------|-------|-------|---------|-------------|--------|----------|------|-----------|
| Phase 1 | 0     | 99999 | 0.04457 | 18.95       | PASS   | 5        | 0.3  | PASS      |
| Phase 2 |       |       | 0.04442 |             | PASS   |          |      |           |
| Phase 3 |       |       | 0.04446 |             | PASS   |          |      |           |

## SURGE TEST

|  | V | Toll% L | L | dL % | Toll% Q | Q | dQ % | Result | T Q F % |
|--|---|---------|---|------|---------|---|------|--------|---------|
|  |   |         |   |      |         |   |      |        |         |
|  |   |         |   |      |         |   |      |        |         |
|  |   |         |   |      |         |   |      |        |         |
|  |   |         |   |      |         |   |      |        |         |

## H. V. TEST

|  | V (V) | I Max (A) | I Meas(A) | Result |
|--|-------|-----------|-----------|--------|
|  | 1523  | 0.004     | 0.304     | GO     |

## MEGAOHMMETER TEST

|  | V (V) | R Min [kOhm] | R Meas [kOhm] | Result |
|--|-------|--------------|---------------|--------|
|  | 1525  | 1000         | 45            | GO     |

## SURGE 1.2/50 TEST

|  | V PK (V) | V 50u | Result |
|--|----------|-------|--------|
|  |          |       | N.E.   |

## POLARIZATION INDEX TEST

|  | V PK (V) | Ri | Rf | K | Time (s) |
|--|----------|----|----|---|----------|
|  |          |    |    |   |          |

