

DATE

16/04/2015

PRODUCER

R.E.M. SRL

CUSTOMER

SORGENIA APRILIA

PRODUCT

ABB13MAG10AN005MATR.36C

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.0441	18.73	PASS	5	1.3	PASS
Phase 2			0.0444		PASS			
Phase 3			0.04381		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1511	0.004	0.304	GO

MEGAOHMMETER TEST

	V (V)	R Min [kOhm]	R Meas [kOhm]	Result
	1525	1000	45	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
			N.E.

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

