

DATE

26/01/2017

PRODUCER

R.E.M. SRL

CUSTOMER

SORGENIA

PRODUCT

ABB10PGB11AP001 MATRICOLA
N°3GF10029785

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.01561	14.46	PASS	5	0.2	PASS
Phase 2			0.01565		PASS			
Phase 3			0.01563		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1562	0.004	2	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1550	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	1446	750	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

