

DATE

14/05/2018

PRODUCER

R.E.M. SRL

CUSTOMER

SORGENIA APRILIA

PRODUCT

10PGC11AP001 ABB Tp
M3BB315MLA4 N°3GF10029785

RESISTANCE TEST

	R min	R max	R	Temperature	Result	max dR %	dR %	Result dR
Phase 1	0	99999	0.01636	17.71	PASS	18.5	0.3	PASS
Phase 2			0.01632		PASS			
Phase 3			0.01634		PASS			

SURGE TEST

	V	Toll% L	L	dL %	Toll% Q	Q	dQ %	Result	T Q F %

H. V. TEST

	V (V)	I Max (A)	I Meas(A)	Result
	1055	0	0.1	GO

MEGAOHMMETER TEST

	V (V)	R Min [MOhm]	R Meas [MOhm]	Result
	1054	1000	5	GO

SURGE 1.2/50 TEST

	V PK (V)	V 50u	Result
	696	428	GO

POLARIZATION INDEX TEST

	V PK (V)	Ri	Rf	K	Time (s)

